

## BACKDRAUGHT DAPMER KOM ... U SERIES

## **INSTALLATION GUIDE**

INSTALLATION

TOOLS REQUIRED









Aluminium tape


#### DAMPER POSITIONING IN THE AIR DUCT


Swivel axsi of the blade must be positioned vertially.

The air damper must be installed in the ventilation system considering the air flow direction.

### MOUNTING WITH CLAMPS


Connect the air damper with flexible air ducts and fix the air ducts to the damper using the clamps.





# MOUNTING WITH A MOUNTING ALUMINIUM TAPE

Connect the air damper with air ducts and fix the connection place using a mounting tape.





Vents-US 400 Murray Road, Cincinnati, OH 45217, USA Tel: 1-888-640-0925, 513-583-5786, Fax: 513-268-4597 E-mail: support@ventsus.com

MIU\_63\_KOM\_U\_EN-01